

## Addendum #1 – Questions / Answers RFP #26-0116-01

1. Are there specific bonding requirements for this job?
  - a. Bid Bond @ 7.5%, Performance @ 5%, Payment @ 100%
2. Are the meters already installed in the ground on setters?
  - a. The meters are already installed in the ground.
3. If a current box or lid is in disrepair, is there a set adder for replacements? Additionally, who is responsible for providing the new Boxes or Lids?
  - a. Yes, at completion we will add all repair units to the total through a change order. Winning bidder would be responsible.
4. If concrete or asphalt around meter boxes must be removed, should this be handled as an adder or a change order?
  - a. If concrete or asphalt is around a meter, removal should be handled by the installer.
5. For the 2" and 3" installations, are 2-bolt flanges used? Are ribbed gaskets required, or are standard drop-ins acceptable?
  - a. The 2" and 3" meters do have bolt flanges, and standard drop in gaskets will be acceptable.
6. Is an address list available, specifically for locations requiring 2" meters and above?
  - a. Yes, an address list is available for the locations requiring 2" meters and above and can be provided upon request.
7. Does the vendor need to be licensed in the state of Georgia?
  - a. The vendor is required to be licensed in the State of Georgia.