



**CITY OF DUBLIN
ADDENDUM #1
RFP #26-0417-01
#1 AND #2 SECONDARY SETTLING BASIN REHABILITATION**

DATE: May 12, 2026

TO: #1 and #2 Secondary Settling Basin Rehabilitation Proposers

FROM: David Sawyer, Purchasing Director

SUBJECT: Questions & Answers

Question: Do you have any record of the gearboxes used on the basin with the SEW motors. There are 2 gearboxes that makeup one complete unit. I only have the motor ID plate for the SEW motor and do not have any ID plates for the gearboxes, and my rep needs more information. Will you be posting an addendum with is information. The equipment is badly weathered with no visible ID plates.

Answer:

Amtech Drives is pleased to quote the following:

Item #	Model #	Description
1	SEW-R57 R37 DRN71M4/DH	GEAR BOX & MOTOR
2		
3		



SEW-EURODRIVE
45373 Troy, OH - USA
R57 R37 DRN71M4
87.8688958701.0001X26.50 Inverter duty VPWM 3ph IEC60034
Hz 60 rpm 1730/1.2 v230/460 YY/Y
hp 0.50 S1 A1.83/0.91 eff% 78.5 IE3
Duty S1 PF 0.62 SF 1.15 IP 66 TEFC
Th.CL 155(F) KVA-Code K
Cr 300-1800rpm ML 85
i 1399 lb-in 18900 MtgPos M1
CLP HC 220 Synth. Oil/1.70/0.35 l
lb 85.367 AMB °C -20..40 1883781.RN



SEW-EURODRIVE
45373 Troy, OH - USA
R57 R37 DRN71M4
87.8688958701.0001X26.50
no open 1.2 no open 1730
Ma max lb-in 3980
i 1399
MtgPos M1
CLP HC 220 Synth. Oil/1.70/0.35 l 1876 124 0

Be sure to submit this signed form with your proposal to acknowledge your receipt of the addendum. Failure to return signed addendum may result in disqualification of proposal.

I have read the above change to the original bid and will submit my bid accordingly.

Bidder: _____

Signature

Date